

Lichfield DAC Delegated Authority Consultation Form

OFS application ref *

(e.g. 2022-012345)

2024-097887

Name of church *

(e.g. Ellesmere, St Mary)

Mavesyn Ridware: St Nicholas

Net zero carbon

If the proposal involves a matter to which [net zero guidance](#) applies, the applicants must have had due regard to that guidance

Does the proposal involve a matter to which net zero guidance applies? *

(i.e. heating and/or lighting)

☒ Yes

☐ No

Net zero guidance

The proposal must include an explanation of how the applicants, in formulating the proposal, have had due regard to [net zero guidance](#)

The applicant's explanation of having had due regard to net zero guidance is *

Please select one of the following two statutory options

- ☒ Adequate
- ☐ Not adequate

Reasons for not being adequate

Reasons on the DAC Notification of Advice *

The following reasons for the applicant's explanation not being adequate should be included on the DAC Notification of Advice

.....

Approval by Chancellor

Do you recommend this application for approval by the Chancellor? *

Please select one of the following three statutory options

- ☐ Recommend
- ☐ Not object
- ☒ Not recommend

Provisos

Provisos for the DAC Notification of Advice (optional)

The following provisos should be included on the DAC Notification of Advice

see previous answer

.....

Reasons for not objecting

Reasons for the DAC Notification of Advice (optional)

The following reasons for not objecting to the application should be included on the DAC Notification of Advice

Reasons for not recommending

Reasons for the DAC Notification of Advice *

The following reasons for not recommending the application should be included on the DAC Notification of Advice

ONLY reviewed lighting, I would not recommend as they are using flood lights which are quite an industrial feel, but also these ones are 4000k. I would recommend they pick something with a warmer colour rendering (around 3000k) other than that I have no objections to the proposal.

External formal consultation

Is formal consultation with external statutory bodies required? *

*Consultation is required if the work or part of the work proposed is **likely** to affect the character of a listed church building or archaeological remains within a church or churchyard*

☐ Yes

☒ No

External formal consultation

Which of the following is the work or part of the work proposed **likely** to affect? *

Please select as many of the following statutory options that apply

- ☐ The character of the church as a building of special architectural or historic interest
- ☐ The archaeological importance of the church
- ☐ Archaeological remains existing within the church or its curtilage

External formal consultation undertaken

The following bodies have been consulted on the works or other proposals *

Please select as many of the following statutory options that apply

- ☐ Historic England
- ☐ Local Planning Authority (Conservation Officer)
- ☐ Local Planning Authority (County Archaeologist)
- ☐ Council for British Archaeology
- ☐ Historic Buildings & Places [AMS]
- ☐ Society for the Protection of Ancient Buildings
- ☐ Georgian Group
- ☐ Victorian Society
- ☐ Twentieth Century Society
- ☐ Church Buildings Council

Objections raised

Have formal objections been raised by any of the external bodies consulted? *

Please select one of the following three statutory options

- ☐ No objections have been raised by any of them
- ☐ Objections were raised but have been withdrawn
- ☐ Objections have been raised and have not been withdrawn

Objections not withdrawn

The reasons for the DAC recommending/not objecting to the application being approved despite those objections are *

The following reasons should be included on the DAC Notification of Advice

Comments

General comments about this application (optional)

*The following general remarks are **not for action by the parish or decision by the Chancellor**, but simply to provide any additional context to your consultation response*

It is a very basic solution, hence not insisting on insisting on proper lighting design, good to see cabling detailed and considered. Don't let the lights hold up doing the rest of the remedials. Sorry for the delay in responding.

DAC consultee details

Name of consultee *

Heather Loosemore

Role of consultee *

Interium Lighting Advisor

Date form completed *

(To enter today's date, click the calendar icon below and select 'Today')

DD MM YYYY

27 / 06 / 205

This content is neither created nor endorsed by Google.

Google Forms